

## CT - 650 CLEANING TREATMENT

**DESCRIPTION:** A mildly alkaline, water softening detergent specially designed for degreasing and cleaning boilers and for neutralizing the chemical residue after boiler descaling. It is ideally suited for use in aluminum boiler systems and has a pH of 7.5 to 8.

This product contains chelating agents and surfactants to emulsify and remove oily and greasy residue often found in new boiler installations. After proper washing with this product, new boilers perform smoothly and efficiently.

Once the boiler has been washed out and rinsed thoroughly resume normal service with normal boiler treatment programs.

### **DIRECTIONS:**

**Steam Boiler Alkaline Rinse:** Use 1 litre to 100 litres of water in the boiler. Boiler should be filled well above its normal operating level. Raise the boiler temperature to 60°C - 70°C and maintain this temperature for 2 - 4 hours. Very heavy, greasy or oily deposits may require longer treatment or higher temperatures.

After draining, rinse boiler with fresh water and return to normal service.

**Hot Water Recirculating Systems:** Add 1 litre to 100 litres of water in the total system. Circulate for 2-4 hours. Bleed until bleed water is perfectly clear. Once the recirculating system is completely cleaned of residue, add proper boiler treatment compounds.

**FOR COMMERCIAL USE**

